



NOTES:

1. SEWER SERVICE CONNECTION TO SEWER LATERAL SHALL BE BY MEANS OF FLEXIBLE PIPE CONNECTORS (COUPLING AND DONUT TYPE) WHEN JOINING PIPES OF DIFFERENT MATERIAL.
2. SEWER SERVICE PIPE MATERIAL SHALL BE ANY OF THE FOLLOWING: PVC SCH-40 SOLID WALL, ASTM-D3034 WITH GLUED JOINTS
3. IN LIEU OF CONNECTING TO THE WYE FITTING AT THE R/W LINE, THE BUILDING SEWER MAY BE CONNECTED DIRECTLY TO THE 6" CLEANOUT PIPE, USING THE APPROPRIATE FITTINGS AS EXPLAINED IN NOTE 1.
4. AT A DISTANCE APPROXIMATELY 20' FROM THE STRUCTURE NATIVE SOIL (IN LIEU OF ODOT 703.11) WILL BE USED AS BACKFILL FOR APPROXIMATELY 4' TO CREATE AN IMPERMEABLE COMPACTED PLUG.

NO SCALE

	<p>CLERMONT COUNTY SEWER DISTRICT</p>	<p>COMMERCIAL SEWER SERVICE INSTALLATION</p>	<p>DRAWING NO. S4.1</p>
	<p>APPROVED _____ DATE _____</p>		