



RUNG DETAIL

NOTES:

- 1. LADDERS SHALL BE FABRICATED FROM ALUMINUM TUBING, PLATES & BARS CONFORMING TO ALLOY & TEMPER 6061-T6.
- 2. TUBING SHALL HAVE A 1/8" MIN. WALL THICKNESS.
- 1. LADDER MUST BE FASTENED TO WALL AND FLOOR WITH STAINLESS STEEL ANCHORS.

NO SCALE

	CLERMONT COUNTY SEWER DISTRICT	CHAMBER ACCESS LADDER	DRAWING NO. W4.6
	APPROVED _____ DATE _____		