



April 3, 2024

Attn: Shannon Risner
Middle East Fork Regional Wastewater Treatment Works
1003 US 50
Milford, Ohio, 45150

**Re: Middle East Fork Regional Wastewater Treatment Works
Permit - Intermediate
Approval
NPDES
Clermont County
1PK00010*QD**

Subject: Approval of Nonsubstantial Pretreatment Program Modification – Local Limits

Dear Shannon Risner,

On November 30th, 2020, Ohio EPA received a request from Clermont County to review and approve the County’s proposal to continue its current local limits. Based on OAC 3745-3-03(E), the requested modification is considered nonsubstantial. In accordance with OAC 3745-3-03(G), this letter serves as Ohio EPA’s approval of Middle East Fork Regional Wastewater Treatment Works’ implementation of the continuation of the local limits in page 1 of this letter.

Table 1 - Approved Local Limits

Pollutant	Local Limits (mg/L)
Arsenic	0.418
Cadmium	0.39
Chromium (total)	1.9
Chromium (hex)	1.9
Copper	0.8
Cyanide	2.34
Lead	2.22
Mercury	0.002
Molybdenum	1.5
Nickel	2.669
Selenium	0.441
Silver	1.819
Zinc	1.9

April 3, 2024

Subject: Approval of Nonsubstantial Pretreatment Program Modification – Local Limits

If you have any questions, please contact John Minor at 614-644-2027 or by email at john.minor@epa.ohio.gov

Sincerely,

A handwritten signature in black ink that reads "John Minor". The signature is written in a cursive style with a large, looped "J" and "M".

John Minor
Division of Surface Water
Ohio EPA