



Mike DeWine, Governor
Jon Husted, Lt. Governor
Anne M. Vogel, Director

June 28, 2023

Attn: Shannon Risner
Clermont County Lower East
Fork Regional WWTP
1003 US 50
Milford, Ohio 45150

**Re: Lower East Fork Regional Wastewater
Treatment Works
Permit - Intermediate
Approval
NPDES
Clermont County
1PK00009*ND**

**Subject: Approval of Nonsubstantial Pretreatment Program Modification – Local
Limits**

Dear Shannon Risner,

On March 31st, 2022, Ohio EPA received a request from Clermont County Board of Commissioners to review and approve the county's proposal to continue its current local limits.

Based on OAC 3745-3-03(E), the requested modification is considered nonsubstantial. In accordance with OAC 3745-3-03(G), this letter serves as Ohio EPA's approval of Lower East Fork Regional Wastewater Treatment Works' implementation of the continuation of the local limits in page 2 of this letter.

Subject: Approval of Nonsubstantial Pretreatment Program Modification – Local Limits

Table 1 - Approved Local Limits

Pollutant	Local Limits (mg/L)
Arsenic	0.418
Cadmium	0.39
Chromium (total)	1.9
Chromium (hex)	1.9
Copper	0.8
Cyanide	2.34
Lead	2.22
Mercury	0.002
Molybdenum	1.5
Nickel	2.669
Selenium	0.441
Silver	1.819
Zinc	1.9

For additional information in this matter, please contact Tyler Bowman (SWDO) at (937) 285-6357 or Phoebe Low of the Pretreatment Unit at (614) 644 2001 (Phoebe.Low@epa.ohio.gov).

Sincerely,



John Minor
Division of Surface Water
Ohio EPA