



Mike DeWine, Governor
Jon Husted, Lt. Governor
Anne M. Vogel, Director

July 28, 2023

Attn: Shannon Risner
O'Bannon Creek Regional
WWTW
4400 Haskell Lane
Batavia, Ohio 45103

**Re: O'Bannon Creek Regional Wastewater
Treatment Works
Permit - Intermediate
Approval
NPDES
Clermont County
1PK00017**

**Subject: Approval of Nonsubstantial Pretreatment Program Modification – Local
Limit Approval**

Dear Shannon Risner,

On April 26th, 2022, Ohio EPA received a request from Clermont County Board of Commissioners to review and the County's proposal to continue its current local limits.

Based on OAC 3745-3-03(E), the requested modification is considered nonsubstantial. In accordance with OAC 3745-3-03(G), this letter serves as Ohio EPA's approval of O'Bannon Creek Regional Wastewater Treatment Works' implementation of the continuation of the local limits in page 2 of this letter.

Subject: Approval of Nonsubstantial Pretreatment Program Modification – Local Limit Approval

Table 1 - Approved Local Limits

Pollutant	Local Limits (mg/L)
Arsenic	0.418
Cadmium	0.39
Chromium (total)	1.9
Chromium (hex)	1.9
Copper	0.8
Cyanide	2.34
Lead	2.22
Mercury	0.002
Molybdenum	1.5
Nickel	2.669
Selenium	0.441
Silver	1.819
Zinc	1.9

If you have any questions, please contact Phoebe Low at 614-644-2134 or by email at phoebe.low@epa.ohio.gov.

Sincerely,



John Minor
Division of Surface Water
Ohio EPA