

Slug Control Plan Elements 40 CFR 403.8 (f)(2)(vi)

In accordance with 40 CFR 403.8, f, 2, vi, a slug discharge is any discharge of a non-routine, episodic nature, including but not limited to an accidental spill or a non-customary batch discharge. The plan shall contain, at minimum, the following elements:

- (A) Description of discharge practices, including non-routine batch discharges;
- (B) Description of stored chemicals;
- (C) Procedures for immediately notifying the POTW of slug discharges, including any discharge that would violate a prohibition under 40 CFR 403.5(b), with procedures for follow-up written notification within five days (see below);
- (D) If necessary, procedures to prevent adverse impact from accidental spills, including inspection and maintenance of storage areas, handling and transfer of materials, loading and unloading operations, control of plant site run-off, worker training, building of containment structures or equipment, measures for containing toxic organic pollutants (including solvents), and/or measures and equipment for emergency response.

Procedure for Pretreatment Section Notification of Spill or Slug Discharges

The Clermont County Water Resources Department (CWRD) requires the generator to notify the Industrial Pretreatment Program during business hours at (513)965-4800; or the 24-hour emergency number (513)732-5384, immediately of any discharge that gets into the sewer system, to enable countermeasures to be taken to minimize damage to the wastewater treatment system and/or the receiving waters.

The CCWRD further requires a written follow up report, filed by the generator within five (5) calendar days of the incident, with the Industrial Pretreatment Program. The report shall contain the following:

- 1) A description of the discharge, the cause of the upset and the upsets impact upon the user's compliance status.
- 2) The period of noncompliance, including the exact dates and times of noncompliance, and if the noncompliance continues, the time by which the noncompliance is expected to be corrected.
- 3) Any and all steps taken, or to be taken, to reduce, eliminate and prevent recurrence of the noncompliance.

This written report is to be sent to: Clermont County Water Resources Dept.
Industrial Pretreatment Program
1003 US 50
Milford, OH 45150

CCWRD Industrial Pretreatment Program(513)965-4800
After hours Emergency Number..... (513)732-5384