



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Craig W. Butler, Director

July 12, 2016

Re: NPDES Permit No.: 1PK00017*LD
 Pretreatment Program modification - Local
 Industrial Discharge Limitations

Clermont County Board of Commissioners
 389 East Main Street
 Batavia, OH, 45103

Ladies and Gentlemen:

Pursuant to the requirements of Chapter 6111 of the Ohio Revised Code and Ohio Administrative Code 3745-3-03, the Clermont County Board of Commissioners for approval of modification to the O'Bannon WWTP pretreatment program is hereby approved.

Purpose, Expanded: Clermont County proposes to make updates to its industrial discharge limitations so that all three wastewater treatment plants are have the same local limits. The proposed local limits are capable of protecting water quality standards and the operations of the wastewater treatment system.

Parameters	Existing Limits (mg/L)			Proposed Limits (mg/L)
	Middle East Fork WWTP	Lower East Fork WWTP	O'Bannon Creek WWTP	
Arsenic	0.207	0.418	3.37	0.418
Cadmium	0.171	0.39	1.391	0.39
Chromium, total	1.3	1.9	2.5	1.9
Chromium, hexavalent	1.3	1.9	2.5	1.9
Copper	0.786	0.8	None	0.8
Cyanide	0.768	2.34	2.5	2.34
Lead	0.995	3.295	2.5	2.22
Mercury	0.002	0.0013	0.002	0.002
Molybdenum	1.5	0.709	0.987	1.5
Nickel	1.29	2.699	2.5	2.699
Selenium	0.441	0.873	1.11	0.441
Silver	0.385	1.819	2.351	1.819
Zinc	1.5	1.9	2.5	1.9
Oil and Grease	250	200	250	250

This approval is conditioned on Clermont County's compliance with terms of and the commitments made in this modification and the final application for the approval; and with all applicable provisions of the state and federal law governing POTW pretreatment programs. Clermont County's O'Bannon WWTP's NPDES permit will be modified to incorporate terms of and commitments made in the final application.

Clermont County Board of Commissioners