

**Slug Control Plan Elements**  
**40 CFR 403.8 (f)(2)(vi)**

In accordance with 40 CFR 403.8, f, 2, vi, a slug discharge is any discharge of a non-routine, episodic nature, including but not limited to an accidental spill or a non-customary batch discharge. The plan shall contain, at minimum, the following elements:

- (A) Description of discharge practices, including non-routine batch discharges;
- (B) Description of stored chemicals;
- (C) Procedures for immediately notifying the POTW of slug discharges, including any discharge that would violate a prohibition under 40 CFR 403.5(b), with procedures for follow-up written notification within five days (see below);
- (D) If necessary, procedures to prevent adverse impact from accidental spills, including inspection and maintenance of storage areas, handling and transfer of materials, loading and unloading operations, control of plant site run-off, worker training, building of containment structures or equipment, measures for containing toxic organic pollutants (including solvents), and/or measures and equipment for emergency response.

---

**Procedure for Pretreatment Section Notification of Spill or Slug Discharges**

The Clermont County Water Resources Department (CWRD) requires the generator to notify the IWPT Department during business hours at (513)965-4800; After hours emergency number (513)732-5384, immediately of any discharge that gets into the sewer system, to enable countermeasures to be taken to minimize damage to the wastewater treatment system and/or the receiving waters.

The CCWRD further requires a written follow up report, filed by the generator within five (5) calendar days of the incident, with the IWPT Section. The report shall contain the following:

- 1) A description of the discharge, the cause of the upset and the upsets impact upon the user's compliance status.
- 2) The period of noncompliance, including the exact dates and times of noncompliance, and if the noncompliance continues, the time by which the noncompliance is expected to be corrected.
- 3) Any and all steps taken, or to be taken, to reduce, eliminate and prevent recurrence of the noncompliance.

This written report is to be sent to:                      Clermont County Water Resources Dept.  
   IWPT Department  
   1003 US 50  
   Milford, OH 45150

CCWRD IWPT Department – office ..... 513-965-4800  
After hours Emergency Number..... 513-732-5384