

**Local Limits Determination for Lower East Fork Regional WWTP
Local Limits Determination for Middle East Fork Regional WWTP
Local Limits Determination for O'Bannon Creek WWTP**

Summary of Local Limits Determination - 2015

Parameter	Approved July 12, 2016 Local Limits mg/l	Basis for Current Limits
Arsenic	0.418	Sludge
Cadmium	0.390	Sludge
Chromium, Total	1.90	Current
Copper	0.8	Current
Cyanide	2.34	Current
Lead	2.22	Sludge
Mercury	0.002	1997 Limit
Molybdenum	1.5	Sludge
Nickel	2.699	Current
Selenium	0.441	Sludge
Silver	1.819	Sludge
Zinc	1.900	Current
Oil & Grease	250	SUR

*Acronyms:

SUR = Sewer Use Regulations

WQ = Water Quality

Inhib.-Nit. = Process Inhibition – Nitrification

Inhib.-Sludge = Process Inhibition – Activated Sludge

Current = the current Clermont County Sewer IWPT limit